



6 White Dove Ct. Lakewood NJ 08701
Tel- (732)668-9078 Fax – (732)358-0168
Cert # 00407A Cert # 00430E

06/01/2021

To whom it may concern:

Re: Water Samples at 1 Roman Avenue, Jersey City, NJ

We have sampled the drinking water at the above property for lead and copper. Please note the Federal Action Level for lead is 15 ug/l (ppb), and for copper is 1,300ug/l (ppb).

The results were found to be below the action level.

Thank you very much.

Sincerely,

Joseph Perlstein