



6 White Dove Ct. Lakewood NJ 08701  
Tel- (732)668-9078 Fax – (732)358-0168  
Cert # 00407A Cert # 00430E  
Asb # 01200

---

06/27/2022

Re: 1 Romar Avenue, Jersey City, NJ

To whom it may concern,

We have sampled the drinking water at the above property for lead and copper. Please note the Federal Action for lead is 15 ug/l (ppb) and for copper is 1,300 ug/l (ppb).

All results were found to be below the action level

Feel Free to contact us with any questions.

*A. Kinsbursky*

Ariel Kinsbursky  
732-668-9078



30105 Beverly Road  
 Romulus, MI 48174  
 Ph: 734-629-8161; Fax: 734-629-8431

### Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

**Client :** AAA Lead Professionals  
 6 White Dove Court  
 Lakewood, NJ 08701

**Attn :** Joseph Perlstein      **Email :** joe@aaaleadpro.com  
**Phone :** 732-668-9078      **Fax :**

**AAT Project :** 809648  
**Sampling Date :** 06/21/2022  
**Date Received :** 06/22/2022  
**Date Analyzed :** 06/23/2022  
**Date Reported :** 06/24/2022

**Client Project :** 1 ROMAR AVE JERSEY CITY NJ      **Collected By :**

**WSSN :**

**Project Location :** 1 ROMAR AVE JERSEY CITY NJ


Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
7518170	1-1	FOUNTAIN 1ST SAMPLE	LEAD AND COPPER	0	<0.0010	0.0010	Below
7518171	1-2	FOUNTAIN 2ND SAMPLE	LEAD AND COPPER	0	<0.0010	0.0010	Below
7518172	1-3	NRSE RM 1ST SAMPLE	LEAD AND COPPER		<0.0010	0.0010	Below
7518173	1-4	NRSE RM 2ND SAMPLE	LEAD AND COPPER		<0.0010	0.0010	Below
7518174	1-5	MENS RM 1ST SAMPLE	LEAD AND COPPER		<0.0010	0.0010	Below
7518175	1-6	MENS RM 2ND SAMPLE	LEAD AND COPPER		<0.0010	0.0010	Below
7518176	1-7	WMNS RM 1ST SAMPLE	LEAD AND COPPER		<0.0010	0.0010	Below
7518177	1-8	WMNS RM 2ND SAMPLE	LEAD AND COPPER		<0.0010	0.0010	Below
7518178	1-9	TEACHERS RM 1ST SAMPLE	LEAD AND COPPER		<0.0010	0.0010	Below
7518179	1-10	TEACHERS RM 2ND SAMPLE	LEAD AND COPPER		<0.0010	0.0010	Below
7518180	1-11	KIT 1ST SAMPLE	LEAD AND COPPER		<0.0010	0.0010	Below
7518181	1-12	KIT 2ND SAMPLE	LEAD AND COPPER		<0.0010	0.0010	Below
7518182	1-13	CUSTODIAN 1ST SAMPLE	LEAD AND COPPER		<0.0010	0.0010	Below
7518183	1-14	CUSTODIAN 2ND SAMPLE	LEAD AND COPPER		<0.0010	0.0010	Below
7518184	1-15	RM 100 1ST SAMPLE	LEAD AND COPPER		<0.0010	0.0010	Below

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.001 mg/L (ppm) and for Cu is 0.0015 mg/L (ppm).

For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.

EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu

The laboratory operates in accord with NELAP guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
7518185	1-16	RM 100 2ND SAMPLE	LEAD AND COPPER		<0.0010	0.0010	Below
7518186	1-17	RM 102 1ST SAMPLE	LEAD AND COPPER		<0.0010	0.0010	Below
7518187	1-18	RM 102 2ND SAMPLE	LEAD AND COPPER		<0.0010	0.0010	Below

Analyst Signature


Joseph Kenwabikise

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.001 mg/L (ppm) and for Cu is 0.0015 mg/L (ppm).

For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.

EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu

The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.





30105 Beverly Road  
 Romulus, MI 48174  
 Ph: 734-629-8161; Fax: 734-629-8431

**Certificate of Analysis: Copper In Drinking Water by EPA Method 200.5**

**Client :** AAA Lead Professionals  
 6 White Dove Court  
 Lakewood, NJ 08701

**Attn :** Joseph Perlstein **Email :** joe@aaaleadpro.com  
**Phone :** 732-668-9078 **Fax :**


**AAT Project :** 809648  
**Sampling Date :** 06/21/2022  
**Date Received :** 06/22/2022  
**Date Analyzed :** 06/23/2022  
**Date Reported :** 06/24/2022

**Client Project :** 1 ROMAR AVE JERSEY CITY NJ **Collected By :**  
**Project Location :** 1 ROMAR AVE JERSEY CITY NJ

**WSSN :**

Lab Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Copper mg/L (ppm)	Cu Threshold
7518170	1-1	FOUNTAIN 1ST SAMPLE	.EAD AND COPPEF	0	0.0568	Below
7518171	1-2	FOUNTAIN 2ND SAMPLE	.EAD AND COPPEF	0	0.0172	Below
7518172	1-3	NRSE RM 1ST SAMPLE	.EAD AND COPPEF		0.1552	Below
7518173	1-4	NRSE RM 2ND SAMPLE	.EAD AND COPPEF		0.0852	Below
7518174	1-5	MENS RM 1ST SAMPLE	.EAD AND COPPEF		0.1204	Below
7518175	1-6	MENS RM 2ND SAMPLE	.EAD AND COPPEF		0.0433	Below
7518176	1-7	WMNS RM 1ST SAMPLE	.EAD AND COPPEF		0.0975	Below
7518177	1-8	WMNS RM 2ND SAMPLE	.EAD AND COPPEF		0.0485	Below
7518178	1-9	TEACHERS RM 1ST SAMPLE	.EAD AND COPPEF		0.0964	Below
7518179	1-10	TEACHERS RM 2ND SAMPLE	.EAD AND COPPEF		0.0764	Below
7518180	1-11	KIT 1ST SAMPLE	.EAD AND COPPEF		0.1784	Below
7518181	1-12	KIT 2ND SAMPLE	.EAD AND COPPEF		0.0415	Below
7518182	1-13	CUSTODIAN 1ST SAMPLE	.EAD AND COPPEF		0.0760	Below
7518183	1-14	CUSTODIAN 2ND SAMPLE	.EAD AND COPPEF		0.0567	Below
7518184	1-15	RM 100 1ST SAMPLE	.EAD AND COPPEF		0.1163	Below
7518185	1-16	RM 100 2ND SAMPLE	.EAD AND COPPEF		0.0772	Below
7518186	1-17	RM 102 1ST SAMPLE	.EAD AND COPPEF		0.2057	Below
7518187	1-18	RM 102 2ND SAMPLE	.EAD AND COPPEF		0.1448	Below

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.001 mg/L (ppm) and for Cu is 0.0015 mg/L (ppm).  
 For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.  
 EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu  
 The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 06/24/2022


AAT Project: 809648

Lab Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Copper mg/L (ppm)	Cu Threshold
---------------	-------------	--------------------	---------	-----------------	------------------------------	--------------

Analyst Signature

Joseph Kenwabikise

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.001 mg/L (ppm) and for Cu is 0.0015 mg/L (ppm).  
 For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.  
 EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu  
 The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.





30105 Beverly Road  
Romulus, MI 48174  
Ph: 734-629-8161; Fax: 734-629-8431

To : AAA Lead Professionals  
6 White Dove Court  
Lakewood, NJ 08701

AAT Project : 809648  
Client Project : 1 ROMAR AVE JERSEY CITY N  
Date Reported : 06/24/2022

Attn : Joseph Perlstein      Email : joe@aaaleadpro.com  
Phone : 732-668-9078

Project Location : 1 ROMAR AVE JERSEY CITY NJ

Sample	Client Code	Analysis Requested	Completed	Analyst
7518170	1-1	Pb/Cu in Drinking Water	06/23/2022	Joseph Kenwabikise
7518171	1-2	Pb/Cu in Drinking Water	06/23/2022	Joseph Kenwabikise
7518172	1-3	Pb/Cu in Drinking Water	06/23/2022	Joseph Kenwabikise
7518173	1-4	Pb/Cu in Drinking Water	06/23/2022	Joseph Kenwabikise
7518174	1-5	Pb/Cu in Drinking Water	06/23/2022	Joseph Kenwabikise
7518175	1-6	Pb/Cu in Drinking Water	06/23/2022	Joseph Kenwabikise
7518176	1-7	Pb/Cu in Drinking Water	06/23/2022	Joseph Kenwabikise
7518177	1-8	Pb/Cu in Drinking Water	06/23/2022	Joseph Kenwabikise
7518178	1-9	Pb/Cu in Drinking Water	06/23/2022	Joseph Kenwabikise
7518179	1-10	Pb/Cu in Drinking Water	06/23/2022	Joseph Kenwabikise
7518180	1-11	Pb/Cu in Drinking Water	06/23/2022	Joseph Kenwabikise
7518181	1-12	Pb/Cu in Drinking Water	06/23/2022	Joseph Kenwabikise
7518182	1-13	Pb/Cu in Drinking Water	06/23/2022	Joseph Kenwabikise
7518183	1-14	Pb/Cu in Drinking Water	06/23/2022	Joseph Kenwabikise
7518184	1-15	Pb/Cu in Drinking Water	06/23/2022	Joseph Kenwabikise
7518185	1-16	Pb/Cu in Drinking Water	06/23/2022	Joseph Kenwabikise
7518186	1-17	Pb/Cu in Drinking Water	06/23/2022	Joseph Kenwabikise
7518187	1-18	Pb/Cu in Drinking Water	06/23/2022	Joseph Kenwabikise

Reviewed By

Quality Assurance Coordinator - Stephen Northcott

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.

NY State DOH ELAP -Lab ID #11864, Michigan State Lab # 9996

Date Printed: 06/24/2022 6:09PM

AAT Project: 809648

Sample

Client Code

Analysis Requested

Completed

Analyst

---

---

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.

NY State DOH ELAP -Lab ID #11864, Michigan State Lab # 9996

Date Printed: 06/24/2022 6:09PM

AAT Project: 809648



AAA LEAD PROFESSIONALS  
 6 WHITE DOVE CT  
 LAKEWOOD NJ 08701  
 732-668-9078

SAME DAY	24 HR TAT	48 HR TAT	72 HR TAT

*Lead in water & copper*

CHAIN OF CUSTODY

ADDRESS: 1 ROMAR AVE JERSEY CITY NJ

SAMPLE	ROOM	PLACE	AREA	FLOOR
1-1	FOUNTAIN	1 <sup>ST</sup> SAMPLE		
1-2	FOUNTAIN	2 <sup>ND</sup> SAMPLE		
1-3	NURSE ROOM	1 <sup>ST</sup> SAMPLE		
1-4	NURSE ROOM	2 <sup>ND</sup> SAMPLE		
1-5	MEN'S ROOM	1 <sup>ST</sup> SAMPLE		
1-6	MEN'S ROOM	2 <sup>ND</sup> SAMPLE		
1-7	WOMEN'S ROOM	1 <sup>ST</sup> SAMPLE		
1-8	WOMEN'S ROOM	2 <sup>ND</sup> SAMPLE		
1-9	TEACHER'S ROOM	1 <sup>ST</sup> SAMPLE		
1-10	TEACHER'S ROOM	2 <sup>ND</sup> SAMPLE		
1-11	KITCHEN	1 <sup>ST</sup> SAMPLE		
1-12	KITCHEN	2 <sup>ND</sup> SAMPLE		
1-13	CUSTODIAN	1 <sup>ST</sup> SAMPLE		
1-14	CUSTODIAN	2 <sup>ND</sup> SAMPLE		
1-15	ROOM 100	1 <sup>ST</sup> SAMPLE		
1-16	ROOM 100	2 <sup>ND</sup> SAMPLE		
1-17	ROOM 102	1 <sup>ST</sup> SAMPLE		
1-18	ROOM 102	2 <sup>ND</sup> SAMPLE		

TAKEN AND RELINQUISHED BY:

ARIEL KINSBURSKY A. Kinsbur sky

DATE: 6/21/2022

Signature

*3192  
809648*