



6 White Dove Ct. Lakewood NJ 08701
Tel- (732)668-9078 Fax – (732)358-0168
Cert # 00407A Cert # 00430E
Asb. # 01200

March 28, 2016

Re: 1 ROMAR AVENUE, JERSEY CITY, NJ 07305

To whom it may concern,

This is to inform that the water level was tested for lead contamination at the above address and the results were at satisfactory levels.

Feel free to call with any questions.

Thank you,

Joseph Perstein
AAA Lead Professionals



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (856) 303-2500 / (856) 786-5974
<http://www.EMSL.com> cinnaminsonleadlab@emsl.com

EMSL Order: 201602956
CustomerID: LBPA78
CustomerPO:
ProjectID:

Attn: **Joseph Perlstein**
AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

Phone: (732) 668-9078
Fax: (732) 358-0168
Received: 03/21/16 9:50 AM
Collected: 3/12/2016

Project: 1 Raman Ave Jersey City, NJ

Test Report: Lead in Water by Furnace AAS (EPA 200.9)

<i>Client Sample Description</i>	<i>Lab ID</i>	<i>Collected</i>	<i>Analyzed</i>	<i>Lead Concentration</i>
1 Site: Janitors Sink #1	201602956-0001	3/12/2016	3/25/2016	4.0 ppb
2 Site: Janitors Sink #2	201602956-0002	3/12/2016	3/25/2016	<3.0 ppb
3 Site: 1st Grade #1	201602956-0003	3/12/2016	3/25/2016	13 ppb
5 Site: W.F. South #1	201602956-0005	3/12/2016	3/25/2016	12 ppb
6 Site: W.F. South #2	201602956-0006	3/12/2016	3/25/2016	<3.0 ppb

Phillip Worby, Lead Laboratory Manager
or other approved signatory

The test results contained within this report meet the requirements of NELAC unless otherwise noted. This report relates only to those items tested. Samples received in good condition unless otherwise noted. Quality Control Data associated with this sample set is within acceptable limits, unless otherwise noted. "<" (less than) result signifies that the analyte was not detected at or above the reporting limit. Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ NJ-NELAP 03036

Initial report from 03/25/2016 16:52:19